



Oval Dimensions from Round Size Chart

The below table is for use in the design and ordering of Spiral Oval materials. To achieve stretched Spiral Oval, standard Spiral pipe must be manufactured. This pipe is then stretched to the optimal oval dimensions. Please note, oval dimensions other than those listed below may not be achieved with this practice and would require longitudinal seams.



TUBING	MINOR AXIS (Inches)												
	6	8	10	12	14	16	18	20	22	24	26	28	
13	17.2	-	-	-	-	-	-	-	-	-	-	-	-
14	18.8	17.8	-	-	-	-	-	-	-	-	-	-	-
15	20.4	19.3	18.2	-	-	-	-	-	-	-	-	-	-
16	22.07	20.9	19.8	18.6	-	-	-	-	-	-	-	-	-
17	23.5	22.5	21.3	20.2	-	-	-	-	-	-	-	-	-
18	25.1	24.1	22.9	21.8	20.6	-	-	-	-	-	-	-	-
19	26.7	25.6	24.5	23.4	22.2	21.1	-	-	-	-	-	-	-
20	28.3	27.2	26.1	24.9	23.8	22.7	-	-	-	-	-	-	-
22	31.5	30.4	29.3	28.1	27	25.8	24.7	-	-	-	-	-	-
24	34.6	33.6	32.4	31.3	30.1	29	27.9	26.7	-	-	-	-	-
26	37.8	36.7	35.6	34.4	33.3	32.2	31	29.9	28.7	-	-	-	-
28	40.9	39.9	38.7	37.6	36.5	35.3	34.2	33	31.9	30.7	-	-	-
30	44.1	43	41.9	40.8	39.6	38.5	37.3	36.2	35.1	33.9	32.8	-	-
32	47.3	46.2	45.1	43.9	42.78	41.6	40.5	39.4	38.2	37.1	35.9	34.8	-
34	50.4	49.4	48.2	47.1	46	44.8	43.7	42.5	41.4	40.2	39.1	38	-
36	53.6	52.5	51.4	50.3	49.1	48	46.8	45.7	44.5	43.4	42.3	41.1	-
38	56.8	55.7	54.6	53.4	52.3	51.1	50	48.5	47.7	46.6	45.4	44.3	-
40	59.9	58.9	57.7	56.6	55.4	54.3	53.2	52	50.9	49.7	48.6	47.4	-
42	63.1	62	60.9	59.7	58.6	57.5	56.3	55.2	54	52.9	51.8	50.6	-
44	66.3	65.2	64.1	62.9	61.8	60.6	59.5	58.3	57.2	56.1	54.9	53.8	-
46	69.4	68.3	67.2	66.1	64.9	63.8	62.7	61.5	60.4	59.2	58.1	56.9	-
48	72.6	71.5	70.4	69.2	68.1	67	65.8	64.7	63.5	62.4	61.2	60.1	-
50	75.7	74.7	73.5	72.4	71.3	70.1	69	67.8	66.7	65.6	64.4	63.3	-
52	78.9	77.8	76.7	75.6	74.4	73.3	72.1	70.9	69.9	68.7	67.6	66.4	-
54	82.1	81	79.9	78.7	77.6	76.5	75.3	74.2	73	71.9	70.7	69.6	-
56	85.2	84.2	83	81.9	80.7	79.6	78.5	77.3	76.2	75	73.9	72.8	-
58	-	-	86.2	85.1	83.9	82.8	81.6	80.5	79.3	78.2	77.1	75.9	-
60	-	-	-	-	87.1	85.9	84.8	83.7	82.5	81.4	80.2	79.1	-
62	-	-	-	-	-	89.1	88	86.8	85.7	84.5	83.4	82.3	-
64	-	-	-	-	-	-	91.1	90	88.8	87.7	86.6	85.4	-
68	-	-	-	-	-	-	-	-	95.2	94	92.9	91.7	-
72	-	-	-	-	-	-	-	-	-	-	99.2	98.1	-

INNOVATIVE ♦ PROGRESSIVE ♦ CONSISTENT

460 Grim Lane, Suite 2, York, PA 17406 MAIN 717-764-9090 FAX 717-764-8182